



NOTE: INSTALL METER BASE 11' FROM BOTTOM OF POLE TO OBTAIN METER CLEARANCE OF 5' to 6' FROM GROUND WHEN POLE IS SET

IF BACKBOARD IS USED, USE MINIMUM 3/4" TREATED BOARD

NOTE: EQUIPMENT BOND GROUND IS REQUIRED ON SERVICE CONNECTION FROM MAIN SWITCH ON METER POLE TO SWITCH BOX IN MOBILE HOME.

MINIMUM-30' CLASS 6 TREATED POLE LESS THAN 5 YEARS OLD AND IN SOUND CONDITION

DRAWN BY: D. LITTLE  
 ENG. APPR: B. SEALS  
 DATE: 6/11/25 COUNTY:  
 SCALE: N.T.S. TSR:

**BALDWIN EMC**  
 19600 HWY 59  
 SUMMERDALE, AL 36580 251.989.6247

SIZE: **A**  
 TITLE: INSTALLATION  
 100 AMP METER POLE