



NOTE: TEMPORARY POLE IS NORMALLY GOOD FOR 3 TO 6 MONTHS
 MUST BE A 4x4 16 FOOT TREATED BOARD OR TREATED POLE
 SUBSTANTIAL ENOUGH FOR CLIMBING
 POLE MUST BE BURIED MINIMUM OF 4'

-CONSTRUCTION USE ONLY-
 CONNECTION TO MOBILE HOME
 IS NOT PERMITTED

| | | | |
|--------------|---------|---|----------|
| TITLE: | | INSTALLATION - 60 AMP TEMPORARY POLE | |
| DWN. BY: | DATE: | SCALE: | SHEET OF |
| D. LITTLE | 1/30/07 | N.T.S. | 1 |
| ENG. APPROV: | | | |
| B. SEALS | 1/30/07 | | |