

**LINE EXTENSION OUTLINING UNDERGROUND PRIMARY**

**CONTACT AN EMC ENGINEER BEFORE INSTALLING ANY CONDUIT.**

**SINGLE PHASE INDIVIDUAL RESIDENTIAL PERMANENT SERVICE**

- A. Member or Developer to install 3" schedule 40 gray electrical PVC.
- B. Conduit must be buried a minimum of 48".
- C. Pull line or string must be installed in conduit.
- D. Cooperative to install 0' – 650' of #2 primary conductor at No Cost (Unless overhead primary is also required).
- E. If more than 650' of #2 primary is needed, then Cooperative will install at \$5.00 per foot for each additional foot over 650'.
- F. Transformer Cost:       25 kVA – No Charge  
                                      50 kVA - \$4,125.00
- G. A single door cabinet and associated equipment is \$2,125.00. This equipment may be required depending on distance and design requirements.

**ALL OTHER CLASSES OF UNDERGROUND SERVICE**

- A. Member or Developer to furnish and install all conduit to Cooperative specifications. (3", 4", or 6" schedule 40 gray electrical pvc conduit)
- B. Conduit must be buried a minimum of 48".
- C. Pull line or string must be installed in conduit.
- D. Cooperative to install primary conductor for prices listed below:
  - a. Single Phase Primary Conductor
    - i. #2 Primary in 3" conduit:       \$5.00 / Foot
    - ii. 1/0 Primary in 3" conduit:     \$6.50/ Foot
  - b. Two Phase Primary Conductor
    - i. #2 Primary in 4" conduit:     \$10.00 / Foot
    - ii. 1/0 Primary in 4" conduit:    \$12.75/ Foot
  - c. Three Phase Primary Conductor
    - i. #2 Primary in 4" conduit:     \$14.75 / Foot
    - ii. 1/0 Primary in 4" conduit:    \$19.00 / Foot
    - iii. 4/0 Primary in 4" conduit:   \$20.75/ Foot
- \* ALL OTHER PRIMARY CONDUCTOR: FULL COST
- E. All other associated equipment is full cost.

**NOTE: NO MORE THAN TWO (2) 90 DEGREE SWEEPS WILL BE PERMITTED**

**NOTE: BALDWIN EMC RESERVES THE RIGHT TO INSPECT FOR PROPER INSTALLATION OF CONDUIT.**

REVISED: May 18, 2023