

LINE EXTENSION POLICY OUTLINING OUTDOOR LIGHTS

**CONTACT AN EMC ENGINEER BEFORE INSTALLING ANY CONDUIT.
CONTACT EMC ENGINEERING OFFICE FOR DETAILS.**

- I. INSTALLATION OF A 50 WATT LED IS \$210. ALL OTHER OUTDOOR LIGHT INSTALLATIONS ARE FULL COST.**
- II. INSTALLATION OF WIRE TO SERVE AN OVERHEAD OUTDOOR LIGHT IS \$1.75 PER FOOT. INSTALLATION OF WIRE TO SERVE AN OUTDOOR LIGHT SERVED BY UNDERGROUND IS \$1.50 PER FOOT.**
- III. INSTALLATION OF A POLE TO SERVICE AN OUTDOOR LIGHT.**
 - A. Served by overhead secondary line is \$1,075.00 each.
 - B. Served by underground secondary line in member furnished and installed conduit is \$1,650.00.
 1. Member or developer to install 1" schedule 40 gray electrical PVC with no more than (2) 90 degree sweeps.
 2. Conduit installed at a minimum of 30" deep.
 3. Pull line or string installed in PVC.
- IV. RELOCATION OF AN OUTDOOR LIGHT IS \$210. THERE IS NO CHARGE FOR RELOCATION OF AN OUTDOOR LIGHT WHEN CREW IS ALREADY ON-SITE.**
- V. RELOCATION OF A POLE SERVICING AN OUTDOOR LIGHT THAT IS SERVED BY OVERHEAD SECONDARY IS \$800.**

NOTE: BALDWIN EMC RESERVES THE RIGHT TO INSPECT FOR PROPER INSTALLATION OF CONDUIT.

REVISED: May 18, 2023